

# Protective Rubber Equipment Labeling Chart

for Salisbury Natural Rubber and SALCOR® Rubber Protective Equipment

Class Color	Proof Test Voltage AC / DC	Max. Use Voltage* AC / DC	Rubber Molded Products Label	Insulating Rubber Glove Label	Insulating Rubber Dipped Sleeve Label
<b>00</b> Beige	2,500 / 10,000	500 / 750			
<b>0</b> Red	5,000 / 20,000	1,000 / 1,500			
<b>1</b> White	10,000 / 40,000	7,500 / 11,250			
<b>2</b> Yellow	20,000 / 50,000	17,000 / 25,500			
<b>3</b> Green	30,000 / 60,000	26,500 / 39,750			
<b>4</b> Orange	40,000 / 70,000	36,000 / 54,000			

## ASTM Specification Reference

D120	Rubber Insulating Gloves
D178	Rubber Insulating Matting
D1048	Rubber Insulating Blankets
D1049	Rubber Insulating Covers
D1050	Rubber Insulating Line Hose
D1051	Rubber Insulating Sleeves
F478	In-Service Care of Line Hose & Covers
F479	In-Service Care of Insulating Blankets
F496	In-Service Care of Gloves & Sleeves
F696	Leather Protectors for Insulating Gloves and Mittens
F1236	Inspection Guide for Rubber Products

F1742	PVC Insulating Sheeting
F2320	Rubber Insulating Sheeting
F2677	Electrically Insulating Aprons
Type I-	Designates natural rubber.
Type II-	Designates SALCOR® UV and ozone resistant rubber.

\* Max. Use Voltage when worn with leather protectors.

Insulating Gloves and Sleeves must have a color coded label to meet appropriate ASTM Specifications.

**SALISBURY**  
by Honeywell